

PHILIPS





ExpertResults

7000



PHILIPS
sonicare





English 6

简体中文 **25**

繁體中文 **45**

Introduction

Congratulations on your new Philips Sonicare power toothbrush! Superior plaque removal, whiter teeth and healthier gums are at your fingertips. Using Sonicare's combination of gentle sonic technology and clinically developed and proven features, you can be confident that you're getting the very best clean, every time. Further support and product registration are available to you at: <http://www.philips.com/welcome>.

Welcome to the Philips Sonicare family!

Intended use

ExpertResults series power toothbrushes are intended to remove adherent plaque and food debris from the teeth to reduce tooth decay and improve and maintain oral health. ExpertResults series power toothbrushes are intended for consumer home use. Use by children should be with adult supervision.

Important safety information

Read this important information carefully before you use the appliance and save it for future reference.

Note: The accessories and features of different models vary. For example, some models come with a sanitizer or are equipped with Bluetooth.

Danger

- Keep the charger and/or sanitizer away from water. Do not place or store the appliance where it can fall or be pulled into a tub or sink.
- Do not immerse the charger and/or sanitizer in water or any other liquid.

- After cleaning, make sure the charger and/or sanitizer is completely dry before you connect it to the wall socket.

Warning

- This appliance can be used by children and persons with reduced physical, sensory or mental capabilities or lack of experience and knowledge if they have been given supervision or instruction concerning use of the appliance in a safe way and understand the hazards involved. Cleaning and user maintenance shall not be made by children without supervision.
- Children shall not play with the appliance.
- Keep the sanitizer out of the reach of children at all times.
- Stop using the sanitizer if the UV light bulb remains on when the door is open. UV light can be harmful to the human eye and skin.
- If the appliance is damaged in any way (brush head, toothbrush handle, charger and/or sanitizer), stop using it.
- The mains cord cannot be replaced. If the mains cord is damaged, discard the charger and/or sanitizer.
- Always replace the charger and/or sanitizer with one of the original type in order to avoid a hazard.
- This appliance contains no user-serviceable parts. If the appliance is damaged, contact the Consumer Care Center in your country (see 'Warranty and support').
- Keep the cord away from heated surfaces.
- Do not use the charger and/or sanitizer outdoors or near heated surfaces.

Caution

- Do not clean the brush head, handle, charger, charger cover or sanitizer in the dishwasher.
- If you have had oral or gum surgery in the previous 2 months, consult your dentist before you use this appliance.
- Consult your dentist if excessive bleeding occurs after using this appliance or if bleeding continues to occur after 1 week of use. Also consult your dentist if you experience discomfort or pain when you use this appliance.
- This Philips appliance complies with the safety standards for electromagnetic devices. If you have a pacemaker or other implanted device, contact your doctor or the appliance manufacturer of the implanted appliance prior to use.
- If you have medical concerns, consult your doctor before you use this appliance.
- This appliance has only been designed for cleaning teeth, gums and tongue. Do not use it for any other purpose. Stop using the appliance and contact your doctor if you experience any discomfort or pain.
- This appliance is a personal care device and is not intended for use on multiple patients in a dental practice or institution.
- Do not use other brush heads than the ones recommended by Philips Sonicare.
- Stop using a brush head with crushed or bent bristles. Replace the brush head every 3 months or sooner if signs of wear appear.
- If your toothpaste contains peroxide, baking soda or bicarbonate (common in whitening toothpastes), thoroughly clean the brush head with soap and water after each use. This prevents possible cracking of the plastic.

- Avoid direct contact with products that contain essential oils or coconut oil. Contact may result in bristle tufts dislodging.
- The UV light bulb of the sanitizer is hot during and immediately after the sanitizing cycle. Do not touch the UV light bulb when it is hot.
- Do not operate the sanitizer without the protective screen in place to avoid contact with a hot UV light bulb.
- If you have used the sanitizer for 3 UV clean cycles in a row, switch it off for at least 30 minutes before you start another UV clean cycle.

Electromagnetic fields (EMF)

This Philips appliance complies with all applicable standards and regulations regarding exposure to electromagnetic fields.

Radio Equipment Directive

Hereby, Philips declares that electric toothbrushes with radio frequency interface (Bluetooth) are in compliance with Directive 2014/53/EU.

The full text of the EU declaration of conformity is available at the following internet address:

www.philips.com/support

The radio frequency interface in this product operates at 13.56 MHz.

The maximum RF power transmitted by the appliance is 30.16 dBm.

Your Philips Sonicare (Fig. 1)

- 1 Hygienic travel cap
- 2 Smart brush head(s)*
- 3 Handle
- 4 Power on/off button

- 5 Intensity light
- 6 Mode/intensity button
- 7 Modes
- 8 Brush head replacement reminder light
- 9 Battery indication
- 10 Charger
- 11 Travel case

*Note: The content of the box may vary based on the model purchased.

Using your Philips Sonicare

Brushing instructions



- 1 Push the brush head firmly onto the handle.

Note: It is normal to see a slight gap between the brush head and the handle.

- 2 Wet the bristles and apply toothpaste.
- 3 Place the toothbrush bristles against the teeth at a slight angle (45 degrees), pressing firmly to make the bristles reach the gumline or slightly beneath the gumline.



Note: Keep the center of the brush in contact with the teeth at all times.

- 4 Press the power on/off button to turn on the Philips Sonicare.
- 5 Apply light pressure to maximize Philips Sonicare's effectiveness and let the Philips Sonicare toothbrush do the brushing for you. Gently move the brush head slowly across the teeth in a small back and forth motion so the longer bristles reach between your teeth. Continue this motion throughout the brushing cycle.



Note: To learn how to brush with specific modes, see 'Modes'.

Note: The bristles should slightly flare. Do not scrub.

Note: A change in sound and vibration from the handle alerts you when you apply too much pressure while brushing.

Note: Your handle will briefly pause its vibration when its time to brush the next section, see 'QuadPacer'.

- 6** To clean the inside surfaces of the front teeth, tilt the brush handle semi-upright and make several vertical overlapping brushing strokes on each tooth.



Your Philips Sonicare toothbrush is safe to use on:

- Braces (brush heads wear out sooner when used on braces)
- Dental restorations (fillings, crowns, veneers)

Brush heads

Your brush heads

To see what type of brush head you have, check the brush head label at the bottom.



Brush head name	DiamondClean	Premium Plaque Control
Brush head label	W	C3

Benefit

Stain removal


Plaque removal

To explore our full range of brush heads, go to **www.philips.com/toothbrush-heads** for more information.

BrushSync Technology (Oslo)

BrushSync technology enables your brush heads to communicate with your handle using a microchip. The symbol at the bottom of the brush head indicates that it is equipped with the BrushSync technology. This enables the following features:

- Brush head mode pairing
- Brush head replacement reminder

**Brushing modes**



Your power toothbrush is equipped with 3 different modes: Clean, White, and Gum Care. Based on the smart brush head you use, the mode will be selected automatically. To manually change the mode, press the mode/intensity button while the toothbrush is off.

Clean**White****Gum Care****Benefit**

Plaque removal

Plaque and surface stains removal

Plaque removal and gum massage

	Clean	White	Gum Care
Re-commended brush head	Premium Plaque Control (C3)	Diamond Clean (W)	Optimal Gum Care (G2)
Re-commended intensity level	3	3	3
Total brushing time	2 minutes	2 minutes and 30 seconds	3 minutes
How to brush	Brush each quadrant for 30 seconds 	Brush each quadrant for 30 seconds,  then brush the front top and bottom teeth for an additional 30 seconds. 	Brush each quadrant for 30 seconds,  then brush along the gumline for an additional minute. 

Note: After you have completed the brushing cycle, you can spend additional time brushing the chewing surfaces of your teeth and areas where

staining occurs. You can also brush your tongue, with the toothbrush turned on or off, as you prefer.

Note: All brush heads work with each mode.

Note: When the Philips Sonicare is used in clinical studies, it must be used in the Clean mode (for plaque and gum claims) or in White mode (for whitening claims), at high intensity, with the EasyStart feature turned off.

Intensity settings

Your power toothbrush comes with 3 different intensity levels: low, medium and high. When attached to the handle, the smart brush head will automatically select the recommended intensity. To manually change the intensity, turn on the handle and press the mode/intensity button.

Features

- EasyStart
- Brush head replacement reminder
- Pressure sensor
- Brush head mode pairing
- QuadPacer

EasyStart


The EasyStart feature gently increases the power of the handle over the first 14 brushings to help you get used to the brushing power of the Philips Sonicare.

The EasyStart feature works with all modes.

Note: The EasyStart feature comes deactivated with your product. To activate EasyStart, see 'Activating or deactivating features'.

Brush head replacement reminder

The handle will track the wear of your brush head. It measures:



- The pressure you apply when you brush
 - The time you have brushed with the brush head
- Once your brush head is no longer effective, the brush head replacement reminder will blink amber. This indicates that it is recommended to change your brush head.

Note: The brush head replacement reminder comes activated with your product. To deactivate this feature, see 'Activating or deactivating features'.

Pressure sensor

Your Philips Sonicare measures the pressure you apply while brushing to protect your gums and teeth from damage.

If you apply too much pressure, the handle will change its vibration until you reduce the pressure.

Note: The pressure sensor comes activated with your product. To deactivate this feature, see 'Activating or deactivating features'.

Brush head mode pairing

Brush heads with BrushSync technology are equipped with an RFID chip. The chip communicates to the handle and automatically pairs it with the recommended mode and intensity.

Note: If you change modes/intensity, the handle will remember the last used setting. If you wish to brush with the recommended setting, you can find the recommended modes/intensity in 'Brushing Modes'.

QuadPacer

The QuadPacer feature indicates via a brief change in vibration when you are supposed to move onto the next brushing section.

The toothbrush will automatically turn off at the end of the brushing session.

Charging and battery status

Charging

- 1 Plug the charger into an electrical outlet.
- 2 Place the handle on the charger.
- 3 The charging indicator will flash green until your toothbrush is fully charged.

Battery status (handle on plugged-in charger)

When placed on the charger, the battery light will flash green based on the current battery level.

LED color	Battery charging status
Flashing green	Charging
Solid green	Fully charged
Off	Fully charged and in sleep mode

When placing the handle on the charger:

- The handle will emit 2 short beeps to confirm the handle is placed properly and the handle starts charging.
- The battery light will flash green to indicate it is charging.
- The handle will show solid green when it is fully charged. In order to preserve the charge, the green light will switch off 30 seconds after the charging process is complete.

Battery status (when handle is not placed on charger)

When removing the handle from the charger, the battery light at the bottom of the handle will indicate the status of the battery.

LED color	Number of beeps	Status
Solid green	n/a	Full
Flashing green	n/a	Medium
Flashing amber	3	Low
Flashing amber	5	Battery empty

Note: Your toothbrush comes pre-charged for first use. After first use, charge for at least 24 hours.

Note: It is OK to leave the handle on the plugged in charger in between brushings. This will not impact the battery life negatively.

Activating or deactivating features

You can activate or deactivate the following features of your toothbrush:

- EasyStart
- Brush head replacement reminder
- Pressure sensor

1 Place the handle on the charger.

2 Press and hold the power button for:

Feature	Press the power button for
EasyStart	3 seconds
Brush head replacement reminder	Up to 5 seconds
Pressure sensor	Up to 7 seconds

3 Let go of the power button when you hear:

Feature	You will hear
EasyStart	1 beep

18 English

Brush head replacement
reminder

1 beep then 2 beeps

Pressure sensor


1 beep, 2 beeps then 3 beeps

If you see the brush head replacement reminder and the battery indicator lights **flashing green** and hear **low to high triple tones**, then the feature had been **activated**.

OR

If you see the brush head replacement reminder and the battery indicator lights **flashing amber** and hear **high to low triple tones**, then the feature had been **deactivated**.

Cleaning

			
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗

Caution: Unplug the charger before you clean it.

Caution: Do not use essential oils to clean the brush heads as this can cause damage.

Caution: Do not use isopropyl rubbing alcohol, vinegar or bleach to clean the handle as this may cause discoloration.

Caution: Do not push on the rubber seal at the top of the handle.

Locating the model number

Look on the bottom of the Philips Sonicare toothbrush handle for the model number (HX751x).

Frequently asked questions

Question	Answer
Is my Philips Sonicare toothbrush water resistant?	Yes. However, do not fully submerge the handle in liquid for an extended period of time.
How often should I clean the connection between the brush head and the handle?	It is recommended to clean this after each brushing, or at least once a week.
Can I leave my Philips Sonicare toothbrush on the charger between brushings?	Yes, you can always keep your Philips Sonicare toothbrush on a plugged-in charger. This will not affect the battery lifetime.
How often can I use my Philips Sonicare toothbrush per charge?	Your Philips Sonicare toothbrush should last 2-3 weeks with standard brushings (2x/day) with a full battery. You do not have to charge your Philips Sonicare toothbrush on a daily basis.

Recycling



- This symbol means that this product shall not be disposed of with normal household waste (2012/19/EU).



- This symbol means that this product contains a built-in rechargeable battery which shall not be disposed of with normal household waste (2006/66/EC). Please take your product to an official collection point or a Philips service center to have a professional remove the rechargeable battery.
- The UV light bulb of the sanitizer contains mercury. Do not throw the UV light bulb away with the normal household waste at the end of its life. Hand it in at an official collection point for recycling.
- Follow your country's rules for the separate collection of electrical and electronic products and rechargeable batteries. Correct disposal helps prevent negative consequences for the environment and human health.

Removing the rechargeable battery at the end of lifetime

Warning: Only remove the rechargeable battery when you discard the appliance. Make sure the battery is completely empty when you remove it. Any attempt to remove the battery will void the warranty.


To remove the rechargeable battery, you need a towel or cloth, a hammer and a flat-head (standard) screwdriver. Observe basic safety precautions when you follow the procedure outlined below. Be sure to protect your eyes, hands, fingers, and the surface on which you work.

- 1 Remove and discard the brush head.
- 2 Deplete the battery until the handle no longer turns on.

22 English




- 3** Cover the entire handle with a towel or cloth.




- 4** Hold the top of the handle with one hand.
5 With your other hand, use your hammer to strike the handle 0.5 inches above the bottom end on all sides to eject the end cap.


Note: You may have to strike it several times to break the internal cap connections.




- 6** Remove the end cap. If the end cap does not release easily, repeat step 3 until the end cap is released.




- 7** Holding the handle upside down with a cloth or towel, push the handle down on a hard surface. If the internal components do not easily release from the housing, repeat step 3 until the internal components are released.




- 8** Remove the rubber battery cover with a screwdriver.



- 9 Wedge the screwdriver between the battery and the internal black frame towards the bottom to separate them.



- 10 Insert the screwdriver between the bottom of the battery and the black frame to break the metal tab connecting the battery to the green printed circuit board. This will release the bottom end of the battery from the frame.



- 11 Grab the battery and pull it away from the internal components to break the second metal battery tab.

Caution: Be aware of the sharp edges of the battery tabs so as to avoid injury to your fingers.



- 12 Cover the battery contacts with tape to prevent any electrical shock from residual battery charge. The rechargeable battery can now be recycled and the rest of the product discarded appropriately.

Warranty and support

If you need information or support, please visit **www.philips.com/support** or read the international warranty leaflet.

Warranty restrictions

The terms of the international warranty do not cover the following:

- Brush heads.
- Damage caused by use of unauthorized replacement parts.

24 English

- Damage caused by misuse, abuse, neglect, alterations or unauthorized repair.
- Normal wear and tear, including chips, scratches, abrasions, discoloration or fading.
- UV light bulb.

说明

新款飞利浦 Sonicare 声波震动电动牙刷，您值得拥有！动动手指便可去除牙菌斑，让牙齿更洁白，牙龈更健康。

Sonicare 声波震动牙刷融合了轻柔声波技术与临床开发和验证，确保您每次使用均可获得出色的清洁效果。有关更多支持和产品注册信息，请访问以下网站：

<http://www.philips.com/welcome>。

欢迎使用飞利浦 Sonicare 声波震动牙刷系列产品！

适合用途

ExpertResults 系列电动牙刷旨在去除牙齿上粘附的牙菌斑和食物残渣，以减少蛀牙，改善和维持口腔健康。

ExpertResults 系列电动牙刷专为消费者家庭使用而设计。儿童应在成人监督下使用。

重要安全信息

使用产品之前，请仔细阅读本重要信息，并妥善保管以供日后参考。

注意：不同型号的附件和功能各不相同。例如，部分型号附带消毒器或配备蓝牙。

危险

- 确保充电器和/或消毒器远离水源。请勿将本产品放置或保存在可能掉落或推入浴缸或水槽的地方。
- 请勿将充电器和/或消毒器浸入水或任何其他液体中。
- 清洁后，务必确保充电器和/或消毒器完全干燥后，再将其连接至电源插座。

警告

- 本产品适合由儿童和肢体不健全、感觉或精神上有障碍或缺乏相关经验和知识的人士使用，但前提是有人对他们使用本产品进行监督或指导，以确保他们安全使用，并且让他们明白相关的危害。不要让儿童在无人监督的情况下对本产品进行清洁和保养。
- 切勿让儿童玩弄本产品。
- 务必始终将消毒器放在儿童接触不到的地方。
- 如果紫外线灯泡在舱门打开时仍亮起，请停止使用消毒器。紫外线灯光可能对人的眼睛和皮肤造成伤害。
- 如果产品受到任何损坏（牙刷头、牙刷柄、充电器和/或消毒器），请勿再使用。
- 不得更换电源线。如果电源线损坏，请丢弃充电器和/或消毒器。

- 应始终使用原装型号的充电器和/或消毒器进行更换，以免发生危险。
- 本产品不包含任何用户可维修的零部件。如果本产品已损坏，请联系您所在国家/地区（请参见“保修和支持”）的客户服务中心。
- 请将电源线远离高温表面。
- 请勿在户外或高温表面附近使用充电器和/或消毒器。

警告

- 请勿使用洗碗机清洁牙刷头、牙刷柄、充电器、充电器盖或消毒器。
- 如果您在前 2 个月中曾做过口腔或牙龈手术，请在使用本产品前先咨询您的牙医。
- 如果使用本产品后牙龈大量出血或在使用 1 周后仍会出血，请咨询您的牙医。如果使用本产品时感觉不适或疼痛，也请咨询您的牙医。
- 本飞利浦产品符合电磁装置的安全标准。有关任何涉及心脏起搏器或其他植入装置的问题，请在使用之前咨询医生或相关植入产品的产品制造商。
- 如果您有医学问题，请在使用本产品前咨询您的医生。

- 本产品的设计仅用于清洁牙齿、牙龈和舌头。请勿将其用作任何其它用途。如果感觉任何不适或疼痛，请停止使用本产品并与医生联系。
- 本产品为私人用品，不可供牙医诊所或机构对多位患者使用。
- 切勿使用非飞利浦 Sonicare 声波震动牙刷推荐的其他牙刷头。
- 请停止使用变形或刷毛弯曲的牙刷头。请每 3 个月更换一次牙刷头，如果出现磨损迹象，应提前更换。
- 如果您所用的牙膏中含有过氧化物、碳酸氢钠或其它重碳酸盐（增白牙膏中的常见成份），则请务必在每次使用后用肥皂和水彻底清洗牙刷头。这可以预防可能出现的塑料破裂。
- 避免与含有精油或椰子油的产品直接接触。接触此类产品可能会导致刷毛脱落。
- 在消毒期间或刚刚消毒完毕时，消毒器的紫外线灯泡温度较高。请勿在紫外线灯泡温度较高时触摸灯泡。
- 请勿在没有正确安装保护屏的情况下操作消毒器，以免接触到发烫的紫外线灯泡。
- 如果消毒器已连续使用了 3 个紫外线清洁周期，请将其至少关闭 30 分钟，然后再开始另外的紫外线清洁周期。

电磁场 (EMF)

本 Philips 产品符合所有有关暴露于电磁场的适用标准和法规。

无线电设备指令

飞利浦特此声明具有射频接口（蓝牙）的电动牙刷符合指令 2014/53/EU。

请在以下网站获取欧盟一致性声明全文：
www.philips.com/support

本产品中射频接口的工作频率为 13.56 兆赫兹。

本产品传输的最大射频功率为
30.16 dBm。

飞利浦 Sonicare 声波震动牙刷（图 1）

- 1 旅行用卫生保护盖
- 2 智能刷头*
- 3 手柄
- 4 开/关按钮
- 5 强度指示灯
- 6 模式/强度按钮
- 7 模式
- 8 刷头更换指示灯
- 9 电量指示灯
- 10 充电器
- 11 旅行收纳盒

*注意：包装盒内物品可能会因所购买型号而异。

使用飞利浦 Sonicare 声波震动牙刷

刷牙说明



- 1 将刷头牢牢地推到牙刷柄上。

注意：刷头与刷柄之间会有小间隙，这是正常的。

- 2 浸湿刷毛并挤上牙膏。

- 3 将牙刷的刷毛以小角度（45 度）放在牙齿上，用力按下以使刷毛接触牙龈或牙龈略下方。



注意：始终将牙刷中间与牙齿接触。

- 4 按电源开/关按钮打开飞利浦 Sonicare 声波震动牙刷。


- 5 对飞利浦 Sonicare 轻轻地施加一点压力以使其发挥最佳效果，然后让飞利浦 Sonicare 为您刷牙。轻柔地将牙刷头在牙齿间来回小幅度缓慢移动，以便长刷毛能清洁牙缝。在整个刷牙周期中连续这样移动即可。

注意：要了解如何使用特定模式刷牙，请参阅“模式”。

注意：刷毛应稍微呈喇叭形，不要过度用力。

注意：当刷牙太过用力时，牙刷柄中将出现声音和振动变化来提示您。

注意：需要清洁下一部位时，牙刷柄振动会暂停片刻，请参阅“QuadPacer”。



- 6 要清洁门牙内表面，请将牙刷柄呈半直立状倾斜，在每颗牙齿上反复垂直震动。



您的飞利浦 Sonicare 声波震动牙刷可安全用于：

- 牙齿矫正器（在牙齿矫正器上使用时，牙刷头磨损较快）
- 修复牙体（补牙、齿冠、烤瓷牙）

刷头

您的刷头

要查看您拥有的刷头类型，请检查底部的刷头标签。




刷头名称	钻石亮白型刷头	智臻洁净刷头
刷头标签	W	C3
作用	去除表面牙渍	去除牙菌斑

要探索我们的全系列刷头，请访问 www.philips.com/toothbrush-heads 了解更多信息。

BrushSync 技术 (Oslo)

BrushSync 技术使刷头能够使用微芯片与牙刷柄进行通信。刷头底部的符号表示刷头采用了 BrushSync 技术。因此可以实现以下功能：


- 刷头模式配对
- 刷头更换指示灯



刷牙模式

您的电动牙刷具有以下 3 种不同的模式：清洁、亮白和护龈。牙刷将根据您所使用的智能刷头自动选择模式。要手动更改模式，请在牙刷关闭时按下模式/强度按钮。

	清洁	亮白	护龈
作用	去除牙菌斑	去除牙菌斑和表面污渍	去除牙菌斑和按摩牙龈
推荐刷头	智臻洁净刷头 (C3)	钻石亮白型刷头 (W)	牙龈护理型刷头 (G2)

	清洁	亮白	护龈
推荐强度级别	3	3	3
总刷牙时间	2 分钟	2 分 30 秒	3 分钟
如何刷牙	每一区域刷 30 秒 	每一区域刷 30 秒，  然后在前排上牙和下牙区域再刷 30 秒。 	每一区域刷 30 秒，  最后沿着牙龈再刷一分钟。 

注意：在完成刷牙周期之后，您可以多花一些时间刷洗牙齿的咀嚼面以及污垢容易出现区域。还可以使用该牙刷清洁舌头，这时可以根据自己的喜好打开或关闭牙刷电源。

注意：所有刷头都可以使用每种模式。

注意：飞利浦 Sonicare 声波震动牙刷用于临床研究时，必须使用高强度清洁模式（适用于去除牙菌斑和牙龈保健需求）或高强度亮白模式（适用于美白需求），同时关闭 EasyStart 刷牙动力增强程序功能。

强度设置

您的电动牙刷提供 3 种不同的强度级别：低、中和高。当连接到牙刷柄时，智能刷头将自动选择推荐的强度。要手动更改强度，请打开牙刷柄并按模式/强度按钮。

功能

- EasyStart 刷牙动力增强程序
- 刷头更换指示灯
- 压力传感器
- 刷头模式配对
- QuadPacer

EasyStart 刷牙动力增强程序

EasyStart 刷牙动力增强程序功能在前 14 次刷牙时会缓慢增加牙刷柄动力，以帮助您适应使用飞利浦 Sonicare 声波震动牙刷的刷牙动力。

EasyStart 刷牙动力增强程序功能适用于所有模式。

注意：本产品出厂时已禁用 EasyStart 刷牙动力增强程序功能。要启用 EasyStart

刷牙动力增强程序功能，请参见“启用或禁用功能”。

刷头更换指示灯

牙刷柄将跟踪刷头磨损情况。它可测量：

- 刷牙时施加的压力
- 使用刷头刷牙的时间

一旦刷头失效，刷头更换指示灯就会呈琥珀色闪烁。这表示建议更换刷头。

注意：本产品出厂时已启用刷头更换指示灯。要禁用此功能，请参阅“启用或禁用功能”。

压力传感器

飞利浦 Sonicare 声波震动牙刷可测量您刷牙时施加的压力，从而防止损伤牙龈和牙齿。


如果刷牙时太过用力，牙刷柄将改变其振动，直到您降低力度。

注意：本产品出厂时已启用压力传感器。要禁用此功能，请参阅“启用或禁用功能”。

刷头模式配对

采用 BrushSync 技术的刷头配备了 RFID 芯片。此芯片与牙刷柄通信并自动为其匹配推荐的模式和强度。

注意：如果您更改模式/强度，则牙刷柄将记住上次使用的设置。如果您希望使用



推荐的设置来刷牙，则可以在“刷牙模式”中查找推荐的模式/强度。

QuadPacer

当您应该移到下一个刷牙部位时，QuadPacer 功能会通过短暂的振动变化来进行指示。

牙刷将在刷牙周期结束时自动关闭。

充电与电池状态

充电

- 1 将充电器插入电源插座。
- 2 将牙刷柄放在充电器上。
- 3 牙刷充满电之前，充电指示灯将呈绿色闪烁。

电池状态（牙刷柄置于连接电源的充电器之上）

置于充电器之上时，电池指示灯将根据当前电池电量呈绿色闪烁。

LED 灯的颜色	电池充电状态
绿色闪烁	充电
绿色常亮	充满电
关闭 (Off)	充满电并处于睡眠模式

将牙刷柄放在充电器上时：

- 牙刷柄将发出 2 声短蜂鸣声以确认牙刷柄放置正确并且开始充电。

- 电池指示灯将呈绿色闪烁以表明正在充电。
- 牙刷柄充满电时呈绿色常亮状态。为了保存电量，绿灯将在充电过程完成 30 秒后关闭。

电池状态（牙刷柄未置于充电器之上）

从充电器取下牙刷柄后，牙刷柄底部的电池指示灯将指示电池状态。

LED 灯的颜色	蜂鸣声次数	状态
绿色常亮	不适用	已满
绿色闪烁	不适用	中号
琥珀色闪烁	3	低
琥珀色闪烁	5	电池耗尽

注意：您的牙刷已为首次使用预先充好电。首次使用后，至少需要充电 24 小时。

注意：在电量耗尽之前，可以将牙刷柄放在已连接电源的充电器上。这将对电池寿命产生负面影响。

启用或禁用功能

您可以启用或禁用牙刷的以下功能：

- EasyStart 刷牙动力增强程序
- 刷头更换指示灯
- 压力传感器

1 将牙刷柄放在充电器上。

2 按住电源按钮:

功能	按电源按钮
EasyStart 刷牙动力增强程序	3 秒
刷头更换指示灯	最多 5 秒钟
压力传感器	最多 7 秒钟

3 当您听到以下声音时松开电源按钮:


功能	您将听到
EasyStart 刷牙动力增强程序	1 声蜂鸣音
刷头更换指示灯	1 声蜂鸣音, 然后 2 声蜂鸣音
压力传感器	1 声蜂鸣音, 然后 2 声蜂鸣音, 最后 3 声蜂鸣音

如果您看到刷头更换指示灯和电池指示灯呈绿色闪烁, 并且听到从低至高的三音调, 则表示已启用此功能。

或者

如果您看到刷头更换指示灯和电池指示灯呈琥珀色闪烁, 并且听到从高至低的三音调, 则表示已禁用此功能。

清洁

			
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗

警告： 清洁产品前，请先将充电器电源拔掉。

警告： 请勿使用精油来清洁刷头，因为这可能会造成损坏。

警告： 请勿使用异丙基外用酒精、醋或漂白剂清洁牙刷柄，否则可能导致手柄变色。

警告： 请勿按压牙刷柄顶部的橡胶密封圈。

查询型号

查看飞利浦 Sonicare 声波震动牙刷柄的底部，即可了解具体型号 (HX751x)。

常见问题

问题	回答
我的飞利浦 Sonicare 声波震动牙刷是否具有防水功能？	具有。但是，请勿将牙刷柄长时间完全浸入液体中。
我应该多久清洁一次刷头和牙刷柄之间的连接？	建议每次刷牙后进行清洁，或者至少每周清洁一次。
在电量耗尽之前，我能否将我的飞利浦 Sonicare 声波震动牙刷放在充电器上？	能，您可以始终将飞利浦 Sonicare 声波震动牙刷放在连接电源的充电器上。这不会影响电池寿命。
每次充电后可以按怎样的频率来使用飞利浦 Sonicare 声波震动牙刷？	按照标准刷牙频率（每天 2 次），充满电的飞利浦 Sonicare 声波震动牙刷应该能够持续使用 2-3 周。您不必每天为飞利浦 Sonicare 声波震动牙刷充电。

回收



- 此符号表示该产品不能与一般的生活垃圾一同处理 (2012/19/EU)。



- 此符号表示该产品含有一个内置的充电电池，该电池不能与一般生活垃圾 (2006/66/EC) 一同丢弃。请您将产品送到官方收集中心或飞利浦服务中心，请专业人士移除充电电池。
- 消毒器的紫外线灯泡含有水银。因此，请勿将使用寿命终结的紫外线灯泡与普通生活垃圾一并弃置。请将其交给官方指定的回收中心。
- 遵循您的国家/地区有关分类回收电子电气产品和充电电池的规定。正确弃置产品有助于避免对环境和人类健康造成不良后果。


使用寿命终结时卸下充电电池

警告： 必须在丢弃产品前取出充电电池。在取出电池时请确保电池电量已耗尽并与电源断开连接。自行取下电池会使保修失效。

要拆下充电电池，您需要一块毛巾或布、一个锤子和一个平头（标准）螺丝刀。按照下面列出的步骤执行操作时，请遵循基


本的安全措施。务必保护好您的眼睛、手、手指以及工作台面。

- 1 取下并丢弃牙刷头。
- 2 耗尽电池，直至无法再启动牙刷柄。
- 3 用毛巾或布包住整个牙刷柄。




- 4 用一只手握住牙刷柄的顶部。
- 5 用另一只手拿锤子敲击底部以上 0.5 英寸处的牙刷柄四周，使端盖弹出。

注意：可能需要敲击多次，才能将内部端盖连接分开。



- 6 取下端盖。如果很难取出端盖，请重复步骤 3，直至将其取出。



- 7 用布或毛巾倒过来握住牙刷柄，将牙刷柄向下按到坚硬的表面上。如果很难从外壳中取出内部组件，请重复步骤 3，直至将其取出。

- 该表格中所显示的“有害物质”在产品正常使用情况下不会对人身和环境产生任何伤害。
- 该表格中所显示的“有害物质”及其存在的部件向消费者和回收处理从业者提供相关物质的存在信息，有助于产品废弃时的妥善处理。

保修和支持

如需信息或支持，请访问
www.philips.com/support 或阅读国际保修卡。

保修限制

国际保修条款中不包括以下各项：

- 刷头。
- 因使用未授权的备件而造成的损坏。
- 由于误用、滥用、疏忽、改装或擅自修理造成的损坏。
- 正常磨损，包括裂口、擦痕、磨损、变色或褪色等。
- 紫外线灯泡。

簡介

恭喜您添購了新的飛利浦 Sonicare 電動牙刷！更佳的牙斑菌清除能力、更亮白的牙齒及更健康的牙齦盡在彈指之間。Sonicare 結合了溫柔的音波震動技術以及經臨床研發並證實的功能，讓您每一次使用都能安心享有潔淨的效果。進一步的支援和產品註冊請至下列網址：<http://www.philips.com/welcome>。

歡迎加入飛利浦 Sonicare 的大家庭！

適用用途

ExpertResults 系列的電動牙刷專供清除黏附在牙齒的牙菌斑和食物殘渣，以減少蛀牙，並改善和維持口腔健康。ExpertResults 系列的電動牙刷適合消費者全家使用。必須由成人監督兒童使用。

重要安全資訊

使用本產品前，請先仔細閱讀此重要資訊，並保留說明以供日後參考。

注意：不同機型的配件和功能不盡相同。例如，部分機型隨附殺菌器或配備藍牙。

危險

- 充電器和/或殺菌器請勿沾到水。請勿將本產品放置或存放在可能掉落或扯落至浴缸或水槽的位置。
- 切勿將充電器和/或殺菌器浸泡在水中或其他液體中。
- 清潔之後，請確認充電器和/或殺菌器已完全乾燥，才可連接至牆壁插座。

警示

- 兒童及身體官能或心智能力退化者，或是經驗與使用知識缺乏者，可在有人從旁監督或適當指示如何安全使用本產品，以及瞭解潛在危險的狀況下使用本產品。若無人監督，請勿讓兒童進行清潔和使用後維護。

- 請勿讓小孩把玩本產品。
- 切勿讓兒童接觸殺菌器。
- 殺菌器的門開啟時，若紫外線燈依舊亮著，請停止使用殺菌器。紫外線對人類眼睛與皮膚有害。
- 如果產品有任何機件受損（刷頭、牙刷握柄、充電器和/或殺菌器），請停止使用產品。
- 不可更換電源線。如果電源線損壞，請丟棄充電器和/或殺菌器。
- 請務必更換原型號的充電器和/或殺菌器，以免發生危險。
- 本產品未包含使用者可使用的零件。本產品如有損壞，請聯絡您所在國家/地區（見 '保固與支援'）的客戶服務中心。
- 請讓電線遠離加熱表面。
- 請勿於室外或高熱表面附近使用充電器和/或殺菌器。

警告

- 請勿將刷頭、握柄、充電器、充電器蓋或殺菌器放入洗碗機清洗。
- 如果您曾在過去 2 個月內動過口腔或牙齦手術，在使用本產品前請諮詢您的牙醫。
- 如果您在使用本產品後有出血狀況，或出血狀況延續超過 1 星期，請向您的牙醫諮詢。使用本產品時，如有明顯不適或疼痛，請諮詢牙醫師。
- 本飛利浦產品符合電磁裝置的安全標準。若您裝有心律調節器或其他植入裝置，使用本產品之前請先諮詢醫師或植入裝置製造商。
- 若您有醫療方面的顧慮，使用本產品之前請先諮詢您的醫師。
- 本用品只適用於清潔牙齒、牙齦與舌頭，請勿用於其他用途。如果發生任何不適或疼痛，請停用本產品並就醫。
- 本產品為個人保健用品，不宜在牙醫診所或醫療機構供多名患者使用。
- 請勿使用非飛利浦 Sonicare 推薦的刷頭。

- 若刷頭的刷毛斷裂或彎折，請勿再使用。刷頭請每 3 個月更換，如果有磨損跡象應提前更換。
- 如果牙膏含有過氧化氫、小蘇打或重碳酸鹽 (常見於美白用牙膏)，在每次刷牙完畢後請以肥皂及清水徹底清洗牙刷刷頭。這樣可以防止塑膠裂開。
- 避免直接接觸含有精油或椰子油的產品。以免導致刷毛束鬆脫。
- 殺菌期間與剛完成時，殺菌器的紫外線燈泡具有極高熱度。未降溫前不可碰觸紫外線燈泡。
- 殺菌器未加上護網時請勿操作，以避免與高熱紫外線燈泡接觸。
- 若殺菌器已連續使用 3 個紫外線清潔週期，請先至少關閉 30 分鐘以上，再開始另一個紫外線清潔週期。

電磁波 (EMF)

本Philips產品符合所有電磁場暴露的相關適用標準和法規。

無線電設備指令

飛利浦於此聲明，具備無線電頻率介面 (藍牙) 的電動牙刷符合指令 2014/53/EU。

歐盟符合性聲明的全文可在下列網址取得：

www.philips.com/support

本產品內部的無線電頻率介面運作頻率為 13.56 MHz。

本產品所發射最大 RF 功率為 30.16 dBm。

您的飛利浦 Sonicare (圖 1)


- 1 旅行用衛生保護蓋
- 2 智慧型刷頭*
- 3 握把
- 4 電源開關按鈕
- 5 強度指示燈
- 6 模式/強度按鈕
- 7 模式

- 8 更換刷頭提示燈
- 9 電池指示燈
- 10 充電器
- 11 旅行盒

*注意：包裝內容視購買型號而定。

使用飛利浦 Sonicare

刷牙方法



- 1 將刷頭牢固地推入握把上。

注意：如果刷頭和握柄之間有些微空隙，此屬正常現象。

- 2 沾濕刷毛，然後擠上牙膏。
- 3 將牙刷刷毛略呈傾斜 (45 度) 放置於牙齒表面，用力下壓使刷毛接觸牙齦線或牙齦線稍下方。

注意：隨時讓牙刷中央與牙齒保持接觸。

- 4 按下電源開關按鈕，開啟飛利浦 Sonicare。
- 5 略為施力即可充分發揮飛利浦 Sonicare 的效能，將刷牙的工作交由飛利浦 Sonicare 牙刷為您代勞。將刷頭以輕柔緩慢的小動作在牙齒表面來回移動，讓較長的刷毛能深入牙齒間細縫。刷牙週期當中，請全程持續此動作。

注意：若要瞭解如何使用特定模式刷牙，請參閱「模式」。

注意：刷毛應稍微展開。請勿用力刷。

注意：刷牙時如施壓太過，握把會有聲音和震動變化提醒您。

注意：當您該刷下個部分時，握把會短暫暫停震動，請參閱「QuadPacer」。

- 6 如要清潔門齒內側表面，請直握牙刷握柄，使其呈半傾斜，在每顆牙齒上進行數次垂直重疊的刷拂。



您的飛利浦 Sonicare 牙刷在以下狀態可安全使用：

- 牙齒矯正器 (如果裝有矯正器，牙刷刷毛會較快磨損)
- 牙齒復形 (填補、牙套、牙面鑲嵌)

刷頭 您的刷頭

若要查看您的刷頭類型，請檢查底部的刷頭標籤。




刷頭名稱	DiamondClean	Premium Plaque Control
刷頭標籤	W	C3
優點	清除齒垢	清除牙斑菌

若要探索我們全系列的刷頭，請前往
www.philips.com/toothbrush-heads 以取得詳細資訊。

BrushSync 技術 (奧斯陸)

BrushSync 技術能讓您的刷頭使用微晶片與握柄進行通訊。刷頭底部的符號表示其配備 BrushSync 技術，因而具有下列功能：


- 刷頭模式配對
- 更換刷頭提示燈



刷牙模式

您的電動牙刷配備 3 種不同模式：清潔、亮白和牙齦照護。牙刷將依據您使用的智慧型刷頭自動選擇模式。若要手動變更模式，在牙刷電源關閉時按下模式/強度按鈕。

	清潔	亮白	牙齦照護
優點	清除牙斑菌	清除牙菌斑及表面齒垢	清除牙菌斑及牙齦按摩
建議使用的刷頭	Premium Plaque Control (C3)	Diamond Clean (W)	Optimal Gum Care (G2)
建議使用的強度等級	3	3	3
刷牙時間總計	2 分鐘	2 分鐘 30 秒	3 分鐘

	清潔	亮白	牙齦照護
如何刷牙	每個部位刷 30 秒	每個部位刷 30 秒， 然後上下門牙另外再刷 30 秒。	每個部位刷 30 秒， 然後沿著牙齦線再刷一分鐘。
		 	 

注意：完成刷牙週期後，可多花些時間刷牙齒咬合面及齒垢堆積處。也可隨個人喜好，在牙刷電源啟動或關閉之下刷洗舌頭。

注意：所有刷頭都適用於每一種模式。

注意：若在臨床研究中使用飛利浦 Sonicare，必須在高強度「清潔」模式（以達到牙菌斑及牙齦健康的要求）或高強度「亮白」模式（以達到亮白的要求）中使用，並且關閉 EasyStart 功能。

強度設定

電動牙刷具有 3 種不同的強度等級：低、中和高。接上握柄時，智慧型刷頭會自動選擇建議的強度。若要手動變更強度，請開啟握柄電源並按下模式/強度按鈕。

功能

- EasyStart
- 更換刷頭提示燈

- 壓力感測器
- 刷頭模式配對
- QuadPacer

EasyStart

EasyStart 功能在前 14 次的使用中會緩慢增加握柄的力道，讓您能逐漸適應飛利浦 Sonicare 的刷牙力道。

EasyStart 功能適用於所有模式。

注意：本產品預設關閉 EasyStart 功能。若要啟動 EasyStart，請參閱「啟動或關閉功能」。


更換刷頭提示燈

握柄可追蹤刷頭的磨損狀態。它會測量：

- 您刷牙時施加的壓力
- 使用刷頭刷牙的時間

若刷頭不再有效，更換刷頭提示燈會閃爍琥珀色。這表示建議您更換刷頭。

注意：本產品預設啟動更換刷頭提示燈。若要關閉此功能，請參閱「啟動或關閉功能」。



壓力感測器

飛利浦 Sonicare 會測量您刷牙時施加的壓力，保護您的牙齦與牙齒避免傷害。

如果您過度施力，握柄會有震動變化，直到您減輕壓力為止。

注意：本產品預設啟動壓力感測器。若要關閉此功能，請參閱「啟動或關閉功能」。

刷頭模式配對

具備 BrushSync 技術的刷頭配有 RFID 晶片。此晶片可與握柄進行通訊，並自動與建議的模式和強度配對。

注意：如果您變更模式/強度，握柄會記憶上次使用的設定。如果您想要使用建議的設定刷牙，您可以在「刷牙模式」中找到建議的模式/強度。

QuadPacer

QuadPacer 功能會透過短暫的震動變化，指出您應該移到下一個刷牙區域。

在刷牙階段結束後，牙刷會自動關閉電源。

充電與電池狀態

充電

- 1 將充電器插入電源插座。
- 2 將握柄置於充電器上。
- 3 充電指示燈會持續閃爍綠燈，直到牙刷充飽電力。

電池狀態 (握柄在已經插接電源的充電器上)

放在充電器上時，電池指示燈會根據目前的電池電量閃爍綠燈。

LED 顏色	電池充電狀態
綠燈閃爍	充電
綠燈持續亮起	完全充電
熄滅	完全充電且處於休眠模式

將握柄置於充電器上時：

- 握柄會發出兩聲短嗶聲，以確認握柄放置正確，然後握柄開始充電。
- 電池指示燈會閃爍綠燈，表示正在充電。
- 握柄完全充電後，會持續亮綠燈。為了保留電力，在充電程序完成之後 30 秒，綠燈將會關閉。

電池狀態 (若握柄未放在充電器上)

若從充電器取下握柄，握柄底部的電池指示燈會顯示電池的狀態。

LED 顏色	嗶聲次數	狀態
綠燈持續亮起	無	已滿
綠燈閃爍	無	中

閃爍琥珀色	3	低度
閃爍琥珀色	5	電量耗盡

注意：牙刷已預先充電提供第一次使用。第一次使用之後，請充電至少 24 小時。

注意：刷牙完畢後，可以將握柄留在已經插接電源的充電器上，待下次使用。這不會對電池壽命有不良影響。

啟動或關閉功能

您可以啟動或關閉牙刷的下列功能：

- EasyStart
 - 更換刷頭提示燈
 - 壓力感測器
- 1 將握柄置於充電器上。
 - 2 按住電源按鈕：

功能	按下電源按鈕
EasyStart	3 秒
更換刷頭提示燈	最多 5 秒鐘
壓力感測器	最多 7 秒鐘

- 3 當您聽到嗶聲時，放開電源按鈕：


功能	您會聽到
EasyStart	1 次嗶聲
更換刷頭提示燈	1 次嗶聲，然後 2 次嗶聲
壓力感測器	1 次嗶聲、2 次嗶聲，然後 3 次嗶聲

如果您看到更換刷頭提示燈，電池指示燈閃爍綠燈，而且聽到從低音到高音的三重音，表示功能已經啟動。

或

如果您看到更換刷頭提示燈，電池指示燈閃爍琥珀色，而且聽到從高音到低音的三重音，表示功能已經關閉。

清潔

			
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗
	✓	✓	✗

警告： 進行清潔前，請先拔下充電器電源。

警告： 請勿使用精油清潔刷頭，可能會導致產品損壞。

警告： 請勿使用異丙醇擦拭酒精、醋或漂白劑清潔握柄，以免導致產品變色。

警告： 請勿按壓握柄頂部的橡膠套。

型號的位置

請查看飛利浦 Sonicare 牙刷握柄底部的型號 (HX751x)。

常見問題集

問題	解答
飛利浦 Sonicare 牙刷是否防水？	是。不過，請勿將握柄長時間完全浸在液體中。
刷頭及握柄連接處應多久清潔一次？	建議每次刷牙完畢後清潔，或至少每週清潔一次。
刷牙完畢後，是否可以將飛利浦 Sonicare 牙刷放在充電器上，待下次使用？	可以，您隨時可以將飛利浦 Sonicare 牙刷放在已經插接電源的充電器上。這不會影響電池壽命。
飛利浦 Sonicare 牙刷每次充電可以使用多久？	按照標準刷牙頻率（一日二次），飛利浦 Sonicare 牙刷充飽電後應可持續使用至少 2-3 週。您無需每日為飛利浦 Sonicare 牙刷充電。

回收



- 此符號表示本產品不得與一般家用廢棄物一併丟棄 (2012/19/EU)。



- 此符號表示本產品含有內建充電式電池，不得與一般家用廢棄物一併丟棄 (2006/66/EC)。請將產品攜至政府指定的回收站或飛利浦服務中心，由專業人員取出充電式電池。
- 殺菌器的紫外線燈泡內含汞。紫外線燈泡壽命結束時請勿與一般家庭廢棄物一併丟棄。請將其放置於政府指定的回收站。


- 請按照您所在國家/地區的規定，分類與回收電子電器產品及充電式電池。正確處理廢棄產品有助於避免對環境和人類健康帶來負面影響。

取出壽命結束的充電式電池

警告：請僅在棄置本產品前取出充電式電池。取出電池前，請確認其電力已完全耗盡。試圖取出電池將會使保固失效。


若要取出充電式電池，必須使用毛巾或布、槌子和一字(標準)螺絲起子。進行下列程序時，請遵守基本安全注意事項。務必保護您的眼睛、雙手、手指和工作區域表面。

- 1 取下並棄置刷頭。
- 2 將電池的電力完全耗盡，直到無法再開啟握柄電源為止。
- 3 以毛巾或布覆蓋整個握柄。




- 4 以單手握住握柄頂部。
- 5 用另一隻手拿槌子在握柄底端上方 0.5 吋處敲打握柄四周，以取下尾端蓋。


注意：您可能必須多敲幾下，才能敲斷內蓋連接處。




- 6 移除尾端蓋。如果無法輕易拔下尾端蓋，請重複步驟 3 直到尾端蓋完全鬆脫為止。




- 7 用布或毛巾將握柄上下顛倒握住，在堅硬的表面上將握柄往下壓。如果內部組件無法輕易從外殼鬆脫，請重複步驟 3 直到內部組件鬆脫為止。




- 8 使用螺絲起子取下橡膠電池蓋。



- 9 將螺絲起子卡進電池和內部黑框之間直到底部，將它們分開。




- 10 將螺絲起子伸進電池底部和黑框之間，拉斷連接電池和綠色印刷電路板的金屬突片。這會讓電池底端從框上鬆脫。



- 11 抓住電池，將它拉出內部零件，這樣會拉斷第二個金屬電池突片。

警告： 電池突片的邊緣很銳利，請小心不要弄傷手指。



- 12 用膠帶貼住電池接點，以免殘留的電力造成觸電。
現在可以回收充電式電池，並妥善丟棄產品的其他部分。

保固與支援

如需資訊或支援，請造訪：www.philips.com/support，
或參閱全球保固說明書。

保固限制

下列項目不在全球保固範圍內：

- 刷頭。
- 使用未經授權之更換零件所造成的損害。
- 因不當使用、濫用、疏忽、改裝或未經授權的維修所造成之損害。
- 一般磨損與破損，包括剝落、刮痕、磨損、變色或褪色。
- 紫外線燈泡。

低功率電波輻射性電機管理辦法

第十二條

經型式認證合格之低功率射頻電機，非經許可，公司、商號或使用者均不

得擅自變更頻率、加大功率或變更原設計之特性及功能。

第十四條

低功率射頻電機之使用不得影響飛航安全及干擾合法通信；經發現有干擾

現象時，應立即停用，並改善至無干擾時方得繼續使用。

前項合法通信，指依電信法規定作業之無線電通信。低功率射頻電機須忍

受合法通信或工業、科學及醫療用電波輻射性電機設備之干擾。

— |

| —

— |

| —

— |

| —

— |

| —

www.philips.com/Sonicare

©2019 Koninklijke Philips N.V. (KPNV). All rights reserved. Philips and the Philips shield are trademarks of KPNV. Sonicare and the Sonicare logo are trademarks of Philips Oral Healthcare, LLC and/or KPNV.

3000.037.3865.1 (19/3/2019)



>75 % recycled paper
>75 % papier recyclé